


MAXIMUM VERTICAL HEIGHT IS 5'
MAXIMUM SLOPE PREFERRED 1.5H TO 1V

- NOTES:
1. STEEL TO BE TIED AND CHAIRED AS NECESSARY TO PLACE STEEL IN CENTER OF 5" SECTION.
 2. CONCRETE TO HAVE COMPRESSIVE STRENGTH OF 3,000 psi at 28 DAYS
 3. PLACE CONTRACTION/DUMMY JOINTS AT 20' CENTERS AND MATCH EXPANSION JOINTS IN SIDEWALK. (TYPICAL FOR 4' SIDEWALK).
 4. FENCE POSTS ARE NOT PERMITTED IN THE CONCRETE.

TYPICAL RIP-RAP
ADJACENT TO SIDEWALK
NTS

REVISIONS		
REVISIONS		
 CITY OF ARLINGTON, TEXAS		
PROJECT NUMBER PROJECT NAME (PROJECT LIMITS)		
DATE:	SCALE:	SHEET OF
DESIGNED BY:	DRAWN BY:	CHECKED BY: